



Certificate of Compliance

FIXED EXTINGUISHING SYSTEMS, CLEAN AGENT FIRE EXTINGUISHING SYSTEMS

This certificate is issued for the following:

System Designation:	Sv Series, Mv Series, and Lv Series 3M™ Novec™ 1230 Engineered Fire Suppression Systems
Operation, Design, and Service Manual:	Sv Series, Mv Series, and Lv Series Engineered Fire Suppression Systems Designed For Use With 3M™ Novec™ 1230 Fire Protection Fluid Operation, Design, & Service Manual, DOC108, June 21, 2010

Prepared for: JANUS FIRE SYSTEMS
1102 RUPCICH DRIVE
MILLENNIUM PARK
CROWN POINT, IN 46307

FM Approvals confirms that the products above have been found to comply with the following standard(s): FM Approvals Class 5600 – *Approval Standard for Clean Agent Extinguishing Systems*, February 2009.

Approval Identification: 3037072

Approval Granted: July 22, 2010

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

Richard B. Dunne
Group Manager- Hydraulics
FM Approvals
1151 Boston Providence Turnpike
Norwood, MA 02062

7/22/10
Date



Member of the FM Global Group